

Certificate of constancy of performance

No. 0672-CPR-0089

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the

Construction Product(s) **Electrical hold-open mechanism and sequential closing control
"GEZE E-ISM-guide rail for Boxer size 2-4 and Boxer size 3-6"
with the classification enclosed in the annex 1 of this certificate**

placed on the market
under the name or trade
mark of

**GEZE GmbH
Reinhold-Vöster-Str. 21-29
71229 Leonberg
Germany**

produced in the
manufacturing plant(s)

Plant 01 and Plant 03

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in

Annex ZA
of the standard(s)

EN 1155:1997/A1:2002/AC:2006 and EN 1158:1997/A1:2002/AC:2006

under system

1

for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on **13.12.2016** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

This document has been translated for informative purpose only. Original version is issued in German. In any case of doubt the German version is valid.



(Dr. rer. nat. Stefan Lehner)
Head of Certification Body



Annex 1

to the certificate of constancy of performance No. 0672-CPR-0089

Classification of the guide rail*

EN 1155	3	8	6 3	1	1	4
---------	---	---	--------	---	---	---

EN 1158	3	8**	6 3	1	1	4
---------	---	-----	--------	---	---	---


Note: For door closers with an electrical hold-open mechanism and for door closers with an electrical free swing function a separate door stopper should be provided, if there is a limitation of the opening angle by the use of the device.

* authorized alternative fixation method: clamping assembly by pivoted slot nut

** The door closers "GEZE Boxer size 2-4" and "GEZE Boxer size 3-6" are not door closers with an automatic door opening system (classification 8). Nevertheless, according to DIN EN 1158, chapter 7.2.7.5 the 500.000 cycles (necessary for classification 8) were completed in the way described in the standard.

Stuttgart, 26.08.2019

Material Testing Institute – University of Stuttgart
Department Fire Safety
Certification Body



(Dr. rer. nat. Stefan Lehner)
Head of the Certification Body

